

ATTESTATION OF CONFORMITY

Verification Number : TD56472501

Applicant's Name : EKINGEN ELEKTRONIK PAZ. ITH IHR. SAN. TIC. LTD. STI.

Applicant's Address MAHMUTBEY MAHALLESI 2650. SOKAK NO:1534218 BAGCILAR ISTANBUL

TURKEY

Manufacturer's Name : EKINGEN ELEKTRONIK PAZ. ITH IHR. SAN. TIC. LTD. STI.

Manufacturer's MAHMUTBEY MAHALLESI 2650. SOKAK NO:1534218 BAGCILAR ISTANBUL

Address TURKEY

Product Name : Voice Alarm Control and Indicating Equipment

Product Model/Type (s): DA-240, DA-500, DA-1000, DA-1500, DA-2000, DP-EVAC6000, DP-EVAC6000TP,

DP-EVAC6000RM, DP-EVAC6000BC, DP-EVAC6000KM, DP-EVAC8000, DP-EVAC8000TP, DP-EVAC8000RM, DP-EVAC8000BC, DP-EVAC8000KM, DP-MA6240, DP-RP6000, DP-VCCS6000, DA-EVAC480, DP-EVAC1000, DP-EVAC1000RT, DP-EVAC1000TP, DP-EVAC1000RP, DP-EVAC1000BC,

DP-800LC, DP-EVAC12K, DP-EVAC1000FM

Reference Standard(s): EN 54-16:2008

Brand : DECON

Only System 4 Construction Products Directive (Regulation No. 305/2011)

This verification has been issued in pursuance of the European Commission's note Ref. Ares(2022)6342894-14/09/2022, in respect of voluntary certifications with none-notified procedure. The manufacturer has voluntarily decided to submit its documents concerning the above-mentioned product for verification. Transmission, storage and protection of documents are the responsibility of the manufacturer, as it containing confidential data. The verification activity carried out exclusively concerned the technical documentation and no verification was carried out on the product. This document can not replace the EC Declaration of Performance. Compliance of the product and documentation with the EU directives and standards is the responsibility of the manufacturer. Any significant changes in design and/or production of the product or amendments to the relevant EU directives or standards referred above may render this certificate invalid. The validity of this certificate can be verified on www.eutest.com.tr

Verification issue date : 24/09/2025 Verification expiry date : 23/09/2030







The following conditions are applicable:

Essential Characteristics of EN54-16	EN54-16: 2008 Clauses	Performance
Performance under fire condition	4, 5, 7, 10, 16.5, 16.6, 16.7	Pass
Response delay (response time to fires)	7.1, 7.4, 7.8, 12	Pass
Operational reliability	4, 5, 6, 7, 8, 9, 11, 12, 13, 14	Pass
Durability of operational reliability temperature resistance	16.4, 16.8	Pass
Durability of operational reliability Impact and vibration resistance	16.11, 16.12, 16.13	Pass
Durability of operational reliability Electrical stability	16.14, 16.15	Pass
Durability of operational reliability Humidity resistance	16.9, 16.10	Pass

Implemented optional functions with requirements (per clause of EN54-16):

- 7.3 Audible warning
- 7.5 Phased evacuation
- 7.6.2 Manual silencing of the voice alarm condition
- 7.7.2 Manual reset of the voice alarm condition
- 7.9 Voice alarm condition output
- 8.4 Indication of fault related to voice alarm zones
- 10 Voice alarm manual control
- 12 Emergency microphone(s)
- 13.14 Redundant power amplifiers